



**NOTES:**

1. DISTANCE IS MEASURED FROM THE PROPERTY LINE TO THE FRONT OF THE DWELLING ALONG THE CENTERLINE OF THE SERVICE LINE.
2. SERVICE MUST ENTER BUILDING AT THE POINT CLOSEST TO THE WATER MAIN. IF THE METER IS LOCATED AT THE REAR OF THE BUILDING, THE SERVICE WILL BE TREATED AS IF THE RUN IS LONGER THAN 70'.
3. A METER PIT IS REQUIRED FOR RUNS LONGER THAN 70'.
4. A HOT BOX IS REQUIRED FOR RUNS LONGER THAN 70' IF SERVICE IS LARGER THAN 1" IN DIAMETER.

# SCHEMATIC SINGLE FAMILY HOME

(NOT TO SCALE)

Q:\DEVELOPMENTS\master documents\CAD details\development schematics.dwg

NO.	DATE	REVISION

**SMCMUA**  
SOUTHEAST MORRIS COUNTY  
MUNICIPAL UTILITIES AUTHORITY  
19 SADDLE ROAD  
CEDAR KNOLLS, NJ 07927  
973-326-6100  
www.smcmua.org

**SCHEMATIC  
SERVICE INSTALLATION**

DATE: 1/20/2025	
DESIGNED BY: PAD	CHECKED BY: SD
DRAWN BY: PAD	SCALE: NTS
SHEET: 1 of 1	