



NOTES:

1. BACKFILL TRENCH PER SPECIFICATIONS OR ROAD OPENING PERMIT.
2. SERVICE SADDLES SHALL BE REQUIRED FOR SERVICES THAT ARE 1-1/2" AND 2" DIAMETER.
3. METER PIT SHALL NOT BE LOCATED IN TRAFFIC AREAS. IF DRIVEWAY LOCATION IS UNAVOIDABLE SLAB TYPE CAST IRON FRAME AND COVER (CAMPBELL PATTERN NUMBER 1716) SET IN 30" X 30" X 4" THICK 3,800 PSI CONCRETE SHALL BE USED. A HOLE MUST BE CUT IN LID FOR AMR.

MATERIALS:

1. CORPORATION STOP: MUELLER MODEL B-25008N;
2. CURB STOP: MUELLER MODEL H-15209N ;
3. CURB BOX: BINGHAM AND TAYLOR CO., FIGURE 4901, COMPLETE WITH OLD STYLE LID;
4. SERVICE SADDLE: MUELLER SADDLE SERIES DR2S;
5. METER PIT: MUELLER THERMAL COIL METER BOX
3/4" SERVICE: 250CS1842CCBSN
1" SERVICE: 330CS1842CCBSN;
6. INSULATING PAD: MUELLER 4" THICK CLOSED CELL POLYETHYLENE FOAM
7. TEMPORARY SPACER: SCH 80 PVC, NSF APPROVED OR EQUALS
8. OR EQUALS

Q:\DEVELOPMENTS\master documents\CAD details\2022 standard details.dwg

NO.	DATE	REVISION

SMCMUA
 SOUTHEAST MORRIS COUNTY
 MUNICIPAL UTILITIES AUTHORITY
 19 SADDLE ROAD
 CEDAR KNOLLS, NJ 07927
 973-326-6160
 www.smcmua.org

STANDARD_DETAILS
COPPER_SERVICE

DESIGNED BY: PAD	
DRAWN BY: PAD	
CHECKED BY: SD	
SCALE NTS	
DATE:	SHEET NO.
1/16/2023	1/1